

WaterMan

Promoting Water Recycling in the Baltic Sea Region

The WaterMan project

Feasibility study on dual pipe system for reuse of treated water in public building in Kalmar

Tobias Facchini

Region Kalmar County



Challenge, background and objective

- Area of frequent droughts
- Buildings with existing dual-pipe system
- Hospital with high hygiene requirements

Main objective to study a possible secure system to receive reclaimed wastewater for buildings with a dual pipe system



Public pressurized water well with recovered WW


Production of reclaimed WW in UF-plant



Connection point distribution pipe; 5-6 bar
Dosage of NaOCl to distribution pipe = micorbiological barrier no 2


Pressurized system with UV as
microbiological barrier no 1

Connection point distribution pipe
5-6 bar




Aktuellt förslag för riskvärdering

Tvättthall fordon



Technical design – WATERMAN Dual-pipe



Distribution pipe - WATERMAN KV3



Connection point distribution pipe; 5-6 bar

Dosage of NaOCl to distribution pipe = microbiological barrier no 2

Final review, Elblåg / PL, 24 September 2025

Volymes and area of use

User	Area of use	Consumption					Comment
		m ³ /år	m ³ /dygn	m ³ /h (normal max)	l/min	l/s	
KV3 WC	Toilet flushing	91 250	250	12			365 d/år
Irrigation	Hospital plantations	610	3	2,6			Bevattning förutsätts ske halva ske halva året med 8h/d 8h/d (under natten).
	Hospital gras	3 000	16				
	Hospital new pond	180	1				
Future Ambulance Ambulance	Car wash				50	5-10	Bedöms som högt värde. värde. Bör innebära framtida möjligheter för nyttjande för nyttjande för tvätt.

Final reflections – external consultant

- Biggest surprise – Hygiene experts within Kalmar region had same conclusions as own risk assessment
- Tough moments – solutions more expensive than first predicted
- Tips and insights – during the whole work process crucial to have a transparent and open dialogue with all key stakeholders
- Future wish – Full-scale pilot



Recommendations & next steps

- Aim to proceed to piloting
- Further investigations needs to be carried out
- KSV not in place before 2027
- Estimated and possible financing still unclear
- Stakeholder group needs to be identified and developed





Helpdesk / Contacts for further information:

Tobias Facchini

tobias.facchini@regionkalmar.se

+46 767 858 383

The „BSR Water Recycling Toolbox” was elaborated as part of the project “WaterMan - Promoting water reuse in the Baltic Sea Region through capacity building at local level”, The project is co-financed by the European Union (European Regional Development Fund) and implemented within the Interreg Baltic Sea Region Programme. More information:

eurobalt.org/WaterRecyclingToolbox
interreg-baltic.eu/project/waterman

WaterMan promotes a region-specific approach to water recycling, which intends to use the alternation of too much and too little water that has become typical in the Baltic Sea Region to make the local water supply more resilient, and supports municipalities & water companies in adapting their strategies.

The contents of „BSR Water Recycling Toolbox” are the sole responsibility of the authors and can in no way be taken to reflect the views of the European Union, the Managing Authority or the Joint Secretariat of the Interreg Baltic Sea Region Programme.

